



Ref. Certif. No.

DE 2-042214

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Gird-connected PV Inverter
Name and address of the applicant	SINENG ELECTRIC CO., LTD. No.6, Hehui Road, Huishan District, Wuxi, 214174 Jiangsu, P.R. China
Name and address of the manufacturer	SINENG ELECTRIC CO., LTD. No.6, Hehui Road, Huishan District, Wuxi, 214174 Jiangsu, P.R. China
Name and address of the factory	SINENG ELECTRIC CO., LTD. No.6, Hehui Road, Huishan District, Wuxi, 214174 Jiangsu, P.R. China
Ratings and principal characteristics	Input : 1100Vdc Max, (1)32/32/32/32/32 Adc Max, (2) (3) 32/32/32/40 Adc Max Output: 230/400 Vac, (1) (2) 72.5A, 50kW, (3) 87A, 60kW
Trademark (if any)	SINENG (Logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) SN50PT, 2) SN50PT-B, 3) SN60PT
Additional information (if necessary may also be reported on page 2)	For model differences, refer to test report
A sample of the product was tested and found to be in conformity with	IEC 62109-2:2011 IEC 62109-1:2010
As shown in the Test Report Ref. No. which forms part of this Certificate	CN249VPL 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web : www.tuv.com

Date: 2024-07-15

Signature:

A. Chen

100061 CB 06/2019 HK